ANDREA BLATTY RINIKER Director



## STATE OF WASHINGTON

## DEPARTMENT OF FCOLOGY

7272 Cleanwater Lane, LU-11 • Olympia, Washington 98504-6811 • (206) 753-2353

August 28, 1985

Mr. Martin S. Wirkkala P. O. Box 5 Naselle, Washington 98638

Dear Mr. Wirkkala:

## Water Quality Certification Request

This letter is in response to your request for Water Quality Certification for your hydroelectric Project (Burnham Creek, tributary to Naselle River).

Certification is hereby granted as required by Section 401 of the federal water Pollution Control Act, provided the following conditions are met:

- 1. Prior to completion of the project, the applicant shall evaluate the future operation of the existing clean out gate with respect to compliance with water quality standards during operation of this facility and submit a proposal which addresses the maintenance task of accumulated sediment removal.
- 2. All construction debris will be disposed of on land so it cannot enter state waters.
- 3. Only clean durable riprap will be used.
- 4. Dredge spoils and/or excess excavated material shall be disposed of in a manner that prevents the spoils, or leachates or drainage from the spoils, from entering state waters.
- 5. Oil spill containment and clean up equipment shall be on hand at the power plant at all times.
- 6. A copy of the Hydraulics Project Approval secured from the Washington Department of Fisheries and Game must be submitted to the Southwest Regional Office of this department.
- 7. The project must comply with the instream flow requirements and other terms and conditions set forth in Surface Water Permit No. S 2-26414.

Martin Wirkkala August 28, 1985 Page 2

Failure to comply with the conditions described above may result in revocation of this water quality certification and issuance of civil penalties in accordance with the enforcement policies and guidelines of the Department of Ecology.

Sincerely,

Dennis Lundblad
Division Supervisor
Operations Management
Office of Operations
and Enforcement

DL:pw(gh4/5)

cc: WDOE S.W. Regional Office
Environmental Quality Supervisor
Mike Hambrock, WDOE
Greg Solie, WDOE
Fred Hahn, WDOE
Gary Hanson, WDOE
Kenneth Plumb, FERC

Lon G. Covin Irene Creek Water Power Project FERC No. 10100 Page 7

- I. Mobile equipment that enters the water shall be maintained such that a visible sheen from petroleum products will not appear.
- J. A full time Pollution Control Inspector shall be made available to supervise implementation of the Erosion and Sediment Control Plan.

## V. Additional Requirements

The activities must comply with all conditions contained in the Washington Department of Fisheries or Wildlife Hydraulic Project Approval.

This certification does not relieve the applicant from the responsibility of meeting applicable regulations of other agencies.

If you have any questions, you may contact Robert Newman at 649-7046.

Sincerely,

John H. Glynn

Water Quality Supervisor Northwest Regional Office

RAN: In

cc: Mike Llewelyn, Water Quality Program Manager
Hedia Adelsman, Water Resources Program Manager
Jim Bucknell, Water Resources Supervisor, NWRO
Rodney Sakrison, Hydropower Coordinator, Water Resources Program
Secretary, FERC, Washington, D.C.
Project Engineer, FERC, Portland, Oregon