




STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY

PO Box 47775 • Olympia, Washington 98504-7775 • (360) 407-6300

January 17, 2008

**REGISTERED MAIL RE 130 213 395 US**

Ms. Diana Gritten-MacDonald  
Manager, Environmental Regulatory Services  
Cowlitz County Public Utilities District  
P.O. Box 3007  
Longview, WA 98632



Your address  
is in the  
**Lewis**  
watershed

Re: Swift No. 2 Project

Dear Ms. Gritten-MacDonald:

Enclosed is Amended Order No. 5331. This amendment replaces condition 3 of Amended Order No. 4998 with the language contained in this Amended Order.

All correspondence relating to this document should be directed to Deborah Cornett at Department of Ecology, Southwest Regional Office, P.O. Box 47775, Olympia, WA 98504.

If you have any questions concerning the content of the document, please call Chris Maynard at 360-407-6484.

Sincerely,

Garin Schrieve, P.E.  
Southwest Region Manager  
Water Quality Program

GS:CM:cc(5331)

Enclosure



STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY

IN THE MATTER OF GRANTING A )  
WATER QUALITY CERTIFICATION TO ) AMENDMENT ORDER NO. 5331 of  
Cowlitz County Public Utilities District ) AMENDED ORDER NO. 4998 of  
with Chapter 90.48 RCW and the ) ORDER NO. 3676  
Rules and Regulations of the )  
Department of Ecology )

To: Cowlitz County Public Utilities District  
P.O. Box 3007  
961 12<sup>th</sup> Avenue  
Longview, WA 98632

For the site located at river mile 44 on the Lewis River, Swift No. 2 Dam.

This amendment is issued under the provisions of Chapter 90.48 revised Code of Washington (RCW) and Chapter 173-201A Washington Administrative Code (WAC).

Condition 3 of Amended Order No. 4998, dated December 21, 2007, is hereby amended as follows:

Condition 4.6.5.a of Order 3676 shall be removed and replaced with the following:

Maintain oil sensors on the surface of the water in each sump. Inspect and test these sensors every three (3) months or sooner if needed to insure that they will work as designed. Visually inspect all of these areas each week or immediately if oil is suspected to be present such as in the event of an oil sensor alarm or the observance of an oil or grease spill in the turbine pit of sufficient volume to reach the sump. Oil detected in the sumps by visual inspection or by sensor requires immediate cleanup, and oil in an amount that triggers an oil sensor alarm must immediately be reported to the Emergency Management Division (EMD). (See condition 4.8.3 of Certification Order No. 3676 under Monitoring and Reporting.)

No other conditions or requirements of Order No. 3676 and Amender Order No 4998 is hereby affected by this amendment.

You have a right to appeal this Order. To appeal this you must:

- File your appeal with the Pollution Control Hearings Board within thirty (30) days of the "date of receipt" of this document. Filing means actual receipt by the Board during regular office hours.
- Serve your appeal on the Department of Ecology within thirty (30) days of the "date of receipt" of this document. Service may be accomplished by any of the procedures identified in WAC 371-08-305(10). "Date of receipt" is defined at RCW 43.21B.001(2).

Be sure to do the following:

- Include a copy of this document that you are appealing with your Notice of Appeal.
- Serve and file your appeal in paper form; electronic copies are not accepted.

**1. To file your appeal with the Pollution Control Hearings Board**

Mail appeal to:

The Pollution Control Hearings Board  
P.O. Box 40903  
Olympia, WA 98504-0903

OR

Deliver your appeal in person to:

The Pollution Control Hearings Board  
4224 – 6th Avenue Southeast Rowe Six, Bldg 2  
Lacey, WA 98503

**2. To serve your appeal on the Department of Ecology**

Mail appeal to:

The Department of Ecology  
Appeals Coordinator  
P.O. Box 47608  
Olympia, WA 98504-7608

OR

Deliver your appeal in person to:

The Department of Ecology  
Appeals Coordinator  
300 Desmond Drive Southeast  
Lacey, WA 98503

**3. And send a copy of your appeal to:**


Deborah Cornett  
Department of Ecology  
P.O. Box 47775  
Olympia, Washington 98501

*For additional information visit the Environmental Hearings Office Website: <http://www.eho.wa.gov>*

*To find laws and agency rules visit the Washington State Legislature Website:  
<http://www.leg.wa.gov/CodeReviser>*

Your appeal alone will not stay the effectiveness of this Order. Stay requests must be submitted in accordance with RCW 43.21B.320. These procedures are consistent with Chapter 43.21B RCW.

DATED this 17<sup>th</sup> day of January, 2008, at Olympia, Washington.



Garin Schrieve, P.E.  
Southwest Regional Manager  
Water Quality Program

